

Classification Report Reaction to Fire of Construction Products



Nr. 12-001407-PR03
(KB-K99-01-en-02)

Client
Döllken Weimar GmbH
Werk Bönen
Industriestraße 1
59199 Bönen
Germany

Basis

DIN EN 13501-1:2010-01
Fire classification of construction products and building elements
Part 1: Classification using test data from reaction to fire tests

Notified body
ift Rosenheim GmbH
Theodor-Gietl-Straße 7-9
D-83026 Rosenheim

Notified body No. 0757

Issue No. 2

Object Solid core skirting boards

Designation
Product family "Kernsockelleisten Döllken" (Döllken solid core skirting boards)

Instructions for use

This classification report for reaction to fire defines the classification assigned to the building material according to its product name in conformity with the methods set out by EN 13501-1. This document does not represent type approval or certification of the product.

Validity

The data and results given relate solely to the tested and described specimen.

Notes on publication

The **ift** Guidance Sheet "Conditions and Guidance for the Use of **ift** Test Documents" applies. No part of this document may be used or reproduced as an extract.

Content

This report comprises a total of 4 pages.

- 1 Introduction
- 2 Details of classified product.
- 3 Test reports and test results in support of this classification
- 4 Classification and field of application
- 5 Restrictions



Classification of reaction to fire
DIN EN 13501-1

Class E

ift Rosenheim
05.07.2013

Volker Müller, Dipl.-Ing. (FH)
Head of Testing Department
Fire safety



Dr. rer.nat. Mihaela Buschbeck
Operating Testing Officer
Fire safety

This classification report is the second issue and replaces the first issue No. 12-001407-PR03 KB-K99-01-de-01 dated 11th of June 2013.